

SAFETY AND BUILDINGS DIVISION Plumbing Product Review P.O. Box 2658 Madison, Wisconsin 53701-2658

Jim Doyle, Governor Mary P. Burke, Secretary

June 30, 2004

AQUA TERRA BIOCHEMICAL CORP. OF AMERICA TONY LEWIS 2727 CHEMSEARCH BLVD. IRVING TX SCOTCH CORPORATION LARRY SIEGEL

PO BOX 4466 DALLAS TX 75208

Re: Description: CHEMICAL OR BIOCHEMICAL SEPTIC TANK ADDITIVE

Manufacturer: SCOTCH CORPORATION

Product Name: INSTANT POWER SEPTIC TANK TREATMENT

Model Number(s): NA

Product File No: 20040287

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2009.

This approval is contingent upon compliance with the following stipulation(s):

 This product does not replace the need for a regular program of inspection and maintenance, including having the treatment tank pumped out whenever the sludge and scum occupies one-third of the tank's liquid capacity.

Based on information supplied by the manufacturer and reviewed by the department, this approval recognizes that this plumbing product will not adversely affect bacterial action in the private sewage system, soil hydraulic conductivity in the absorption areas, or groundwater quality beneath the system when used in accordance with the manufacturer's instructions.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Engineering Consultant-Plumbing Product Reviewer
Bureau of Integrated Services
Safety and Buildings Division
Department of Commerce
(608) 267-1401 Phone
(608) 267-9566 Fax
gschlueter@commerce.state.wi.us Email

GWS:gws

SBD-10564-E (N.10/97) File Ref: 04028701.DOC